

ADDENDUM NO. 3

To: Prospective Bidders

Contract: Bid Reference Number 2292

General Construction: Contract No. H2456001
Plumbing Construction: Contract No. H2456002
Mechanical Construction: Contract No. H2456003
Electrical Construction: Contract No. H2456004

Project: Oneida County Department of Public Works
Division of Engineering
Cornell Cooperative Extension
Addition & Alterations
121 Second Street, Oriskany, New York 13424

Prepared By: MARCH Associates, Architects & Planners, PC
258 Genesee Street, Suite 300
Utica, NY 13502

Date: April 24, 2025

This addendum is issued indicating changes to the Contract Documents dated March 13, 2025. All changes shall be incorporated in the Contractor's Proposal as described herein, as this addendum will become part of the Contract Documents, if and when an award is made. Acknowledgment of this addendum shall be indicated on the proposal.

The following changes, additions, and deletions shall be incorporated into the Project Manual and Drawings.

REFER TO THE PROJECT MANUAL:

ITEM 1. ADVERTISEMENT - INVITATION TO BID

- A. **REVISE** Bid Date **FROM:** "Tuesday, April 29th, 2025" **TO READ:** "Thursday, May 8th, 2025".

ITEM 2. SECTION 05 51 00, METAL STAIRS

- A. Page 05 51 00/1, Subparagraph 1.04.B.1 **DELETE** in its entirety.
B. Page 05 51 00/3, Article 3.03 **ADD** the following:

"G. Paint stair. Refer to Section 09 91 23, Interior Painting."

ITEM 3. SECTION 12 24 00, WINDOW SHADES

- A. Page 12 24 00/4, Paragraph 3.07.A. **ADD** the following:

"Shades are not required on CW-04, CW-05, CW-13, CW-16, & CW-17."

REFER TO THE DRAWINGS:

ITEM 1. DRAWING L107, DETAILS

- A. Refer to Detail L/107. **REVISE** wall thickness **FROM:** "2'-0" **TO:** "1'-0""
B. Refer to Detail L/107. **REVISE** Height **FROM:** "1'-6" to "4'-0"" **TO:** "1'-6" to 10 Feet"

ITEM 2. DRAWING A601, DOOR & WINDOW TYPES & DETAILS

- A. Refer to Elevation 10/A601. **ADD** the following note:

"Glass film shall be 3M Prestige PR40X or equal."

* * * * *